

13.04.060 Five-ton capacity system - Limitation on use of water Demand charge.

13.04.060 – Five-ton capacity system - Limitation on use of water – Demand charge.

Any air-conditioning system of over five tons of capacity, installed prior to November 1, 1958, shall be equipped with a water regulating device and may use water from the city mains at a rate not to exceed 0.2 gallons per minute per ton of capacity. The owner of such system shall pay an annual demand charge of twenty dollars per ton of capacity per season for the total tons of capacity over and above five tons, unless the use of water from the city mains for such system shall be limited to a maximum of 0.2 gallons per minute per ton of capacity. This demand charge shall be in addition to the regular charges provided in Section 13.04.100. Charges shall be made for each season for any air-conditioning system not equipped and operating to limit the use of water from the city mains of 0.2 gallons per minute per ton of capacity prior to the first day of May falling within such season.

(Prior code : § 15.403 (D))